



CERTIFICATE NUMBER	24-2535675-PDA
EFFECTIVE DATE	19-Apr-2024
EXPIRY DATE	18-Apr-2029
ABS TECHNICAL OFFICE	Houston ESD - Electrical

# CERTIFICATE OF Product Design Assessment

This is to certify that a representative of this Bureau did, at the request of

## HAMMOND POWER SOLUTIONS INC.

located at

595 SOUTHGATE DRIVE, , GUELPH, ONTARIO, Canada, N1G 3W6

assess design plans and data for the below listed product. This assessment is a representation by the Bureau as to the degree of compliance the design exhibits with applicable sections of the Rules. This assessment does not waive unit certification or classification procedures required by ABS Rules for products to be installed in ABS classed vessels or facilities. This certificate, by itself, does not reflect that the product is Type Approved. The scope and limitations of this assessment are detailed on the pages attached to this certificate.

**Product:** Transformer, Dry Type  
**Model:** Types CK, CKN, CF, CFN, CJ, CG  
**Endorsements:**  
**Tier:** 5 - Unit Certification Required

This Product Design Assessment (PDA) Certificate remains valid until 18/Apr/2029 or until the Rules and/or Standards used in the assessment are revised or until there is a design modification warranting design reassessment (whichever occurs first).

Acceptance of product is limited to the "Intended Service" details prescribed in the certificate and as per applicable Rules and Standards.

This Certificate is valid for installation of the listed product on ABS units which exist or are under contract for construction on or previous to the effective date of the ABS Rules and standards applied at the time of PDA issuance. Use of the Product for non-ABS units is subject to agreement between the manufacturer and intended client.

American Bureau Of Shipping  
*Soheni Haque*  
Soheni Haque, Sr. Managing Principal Engineer

NOTE: This certificate evidences compliance with one or more of the Rules, Guides, standards or other criteria of ABS or a statutory, industrial or manufacturer's standards. It is issued solely for the use of ABS, its committees, its clients or other authorized entities. Any significant changes to the aforementioned product without approval from ABS will result in this certificate becoming null and void. This certificate is governed by ABS Rules 1-1-A3/5.9 Terms and Conditions of the Request for Product Type Approval and Agreement (2010)

**HAMMOND POWER SOLUTIONS INC.**

595 SOUTHGATE DRIVE

GUELPH ONTARIO

Canada N1G 3W6

Telephone: 519 822 2441

Fax: (519) 822-9701

Email: hrazak@hammondpowersolutions.com

Web: www.hammondpowersolutions.com

**Tier: 5 - Unit Certification Required**

---

**Product:** Transformer, Dry Type  
**Model:** Types CK, CKN, CF, CFN, CJ, CG  
**Endorsements:**

**Intended Service:**

Marine and Offshore Applications - intended for use to increase or decrease the alternative voltages in electric power distribution systems on board ships and offshore platforms.

**Description:**

Dry Type Power Transformers:

Cast Resin Types: CJ (open core and coil), CK (enclosed ventilated); CKN (enclosed non-ventilated) transformers and auto transformers, 3- phase;

Cast Resin Types: CG (open core and coil), CF (enclosed ventilated); CFN (enclosed non-ventilated) transformers and auto transformers, 1- phase.

**Rating:**

Type CJ, CK, CKN: 3- phase, 50/60Hz, 46kV class max, 3000kVA max., Class 150, 180, 200C insulation system; Ambient Temp: -20 °C to 40 °C (with derating from 40 °C to 60 °C);

Type CG, CF, CFN: 1- phase, 50/60Hz, 46kV class max, 1500kVA max., Class 150, 180, 200C insulation system; Ambient Temp: -20 °C to 40 °C (with derating from 40 °C to 60 °C);

**Service Restriction:**

1. Unit Certification is required for essential services or emergency services in accordance with 4-8-3/7.3.5 of the Marine Vessels Rules (MVR). For Unit Certification requirements, see "Comments".
2. Transformers of 10 kVA/phase and over are to be provided with effective means to prevent accumulation of moisture and condensation within the transformer enclosure where the transformer is disconnected from the switchboard during standby (cold standby) in accordance with 4-8-3/7.3.4 of the Marine Vessels Rules (MVR).
3. For High Voltage (HV) system, transformer enclosures are to have degree of protection not less than IP23 and if installed in spaces accessible to unqualified personnel the degree of protection is to be increase to IP44 in accordance with 4-8-5/3.7.5(c) of the Marine Vessels Rules (MVR).

**Comments:**

1. The Manufacturer has provided a declaration about the control of, or the lack of Asbestos in this product. If the manufacturer or purchaser request an ABS Certificate for compliance with a specification or standard, the specification or standard, including inspection standards and tolerances, must be clearly defined.
2. All Low Voltage (1 kV or less rated voltage) transformers rated 1 kVA or more (1-phase) and 5 kVA or more (3-phase) intended for essential or emergency services are to be tested by the Manufacturer, whose certificate of tests will be submitted to the Bureau. Routine tests are to include (as a minimum): measurement of winding resistance, voltage ratio, impedance voltage, short circuit impedance, insulation resistance, load loss, no-load loss and excitation current, phase rotation and polarity, dielectric strength and temperature rise for the prototype of each size and type.
3. All three phase High Voltage (more than 1 kV rated voltage) transformers (or 3-phase bank transformers) rated 100 kVA or more are to be tested in the presence of the Surveyor as per IEC 60076 and 4-8-3/7.3.5 and 4-8-5/3.7.5(e) of the Marine Vessels Rules (MVR). Other HV transformers (less than 100 kVA) will be accepted on the basis of a performance test conducted after installation in the presence of the Surveyor.
4. Each transformer is to be provided with a nameplate in corrosion resistant material, showing all data as per 4-8-3/7.3.6 of the Marine Vessels Rules (MVR). In addition, the nameplates of HV transformers are to show information about the applicable standard (IEC 60076) and the short duration power frequency withstand voltage for verification of insulation level of each winding in accordance with 4-8-5/3.7.5(f) of Marine Vessels Rules (MVR).
5. Overvoltage Protection of HV transformers is to be provided by:
  - i) Direct earthing of the lower voltage system;
  - ii) Appropriate neutral voltage limiters, or
  - iii) Earthed screen between primary and secondary winding of transformers.

**HAMMOND POWER SOLUTIONS INC.**

595 SOUTHGATE DRIVE

GUELPH ONTARIO

Canada N1G 3W6

Telephone: 519 822 2441

Fax: (519) 822-9701

Email: hrazak@hammondpowersolutions.com

Web: www.hammondpowersolutions.com

**Tier: 5 - Unit Certification Required**

---

See 4-8-5/3.5.5 of the Marine Vessels Rules.

**Notes/Drawing/Documentation:**

**Terms of Validity:**

This Product Design Assessment (PDA) Certificate remains valid until 18/Apr/2029 or until the Rules and/or Standards used in the assessment are revised or until there is a design modification warranting design reassessment (whichever occurs first).

Acceptance of product is limited to the "Intended Service" details prescribed in the certificate and as per applicable Rules and Standards.

This Certificate is valid for installation of the listed product on ABS units which exist or are under contract for construction on or previous to the effective date of the ABS Rules and standards applied at the time of PDA issuance. Use of the Product for non-ABS units is subject to agreement between the manufacturer and intended client.

**STANDARDS**

**ABS Rules:**

2024 Rules for Conditions of Classification, Part 1, 1-1-4/7.7, 1-1-A3, 1-1-A4, which cover the following:  
2024 Marine Vessel Rules: 4-8-3/7, 4-8-5/3.7.5, 4-8-5/5.17.9

2024 Rules for Conditions of Classification, Part 1 - Offshore Units and Structures 1-1-4/9.7, 1-1-A2, 1-1-A3, which cover the following:  
2024 Mobile Offshore Units Rules: 4-3-5/Table 1, 6-1-7/11

**National:**

CSA C22.2 No. 47-13;  
UL 1562 (2013)

**International:**

N/A

**Government:**

N/A

**EUMED:**

N/A

**OTHERS:**

N/A