



## **Certificate of Conformity**

**We, Hammond Power Solutions Inc., declare that TruWave harmonic filters:**

*Less than and equal to 600 A {floor mount}*

*And*

*Less than and equal to 200 A {wall mount}*

**are designed and manufactured to comply with the specifications,**

*"2018 International Building Code; Section 1613; Earthquake Loads"*  
*and*

*"ASCE 7-16; Chapter 13; Seismic Design Requirements for  
Nonstructural Components"*

**With the site parameters of:**

*Importance Factor: 1.5*

**and**

*Site Class: D = Stiff Soil*

**and**

*$z/h = 1$*

**With the seismic forces defined as:**

*Design Spectral Response Acceleration at Short Periods  
(0.2 second),  $S_{DS} = 2.0$*

**Signed at:** Guelph, Ontario, Canada,  
On the 11th day of August 2025

**Signature:**

A handwritten signature in blue ink, appearing to read "James Luhta".

**Name:** James Luhta, P.Eng.  
Mechanical Engineering Manager - MV  
Hammond Power Solutions Inc.